



# Attestation

## WELL Building Standard™

On the 13<sup>th</sup> of April 2023, Eurofins Product Testing A/S received a sample of tile adhesive with the product name:

### Green Crocodile Tile Adhesive

supplied by

**JORAKAY CORPORATION CO., LTD.**

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the CDPH 01350 (January 2017)/EN 16516 (2017) with EU LCI VOC threshold values and ASTM D2369-20 test standards (See test report no. 392-2023-00172935\_H\_EN and 392-2023-00172936\_XG\_EN).

**The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:**

**VOC emissions specifications:**

- The requirements of the CDPH 01350 v 1.2 (January 2017)

**VOC content specifications:**

- The requirement of SCAQMD Rule 1168 (Adhesives and sealants, 2017) for ceramic glass porcelain, and stone tile adhesive having a VOC content below 65 g/L.

22 May 2023

Liva Kjær Hansen  
Analytical Service Manager

Laura Hartung Sørensen  
Analytical Service Manager

*The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.*