

# Attestation

## LEED v4 and v4.1 BETA

On the 21<sup>st</sup> of March 2023, Eurofins Product Testing A/S received a sample of a paint with the product name:

### Easy Clean Premium

supplied by

## JORAKAY CORPORATION CO., LTD.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350 and ISO 11890-2 testing standards (See test report no. 392-2023-00130601\_H\_EN and no. 392-2023-00130602\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2021) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

#### **VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC between 0.5 – 5 mg/m<sup>3</sup> in both office and class room.

#### **VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): EU Decopaint Directive 2004/42/CE for interior matt walls and ceilings having a VOC content below 30 g/L.

14 April 2023



Liva Kjær Hansen  
Analytical Service Manager



Laura Hartung Sørensen  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*